

~~SECRET~~

9 September 1970

A&RC COMMENTS ON SPECIFICATIONS FOR MOVEABLE SHELVING [REDACTED]

25X1A

1. Add to second sentence of Section 20.1, Page VIII.....operate it under varied loading conditions to demonstrate its loading flexibility before they submit a bid.....
2. Add Section 18.2, Page 3A-6. The 7 foot aisles shall be finished so that they slope for easy access to the adjacent area.
3. Add Section 3.3, Page 14A-2. The system shall be designed so that there are no limitations as to the number of bays that can be operated simultaneously.
4. Add Section 2.5, Page 16A-2. All control boxes shall be installed so that they do not interfere with the placement of boxes on the top shelf or any other shelves.

~~SECRET~~

